

PROCEEDINGS OF THE SUPERINTENDING ENGINEER (GENERAL) i/c
GROUND WATER DEPARTMENT, JALAVIJNANA BHAVAN,
AMBALAMUKKU, THIRUVANANTHAPURAM
(PRESENT: Smt. Rini Rani.S)

Sub: Ground Water Department – Palakkad - Construction of Bore well at Panamkuttu, Parakkulam, Harijan Colony area Ward –XVII, Kizhakkenchery Grama Panchayath in Palakkad District under Groundwater based drinking water supply scheme – sanctioned orders issued.

ORDER NO:- T(1) / 3075/2022/DGW

Dated: 27.07.2022

- Read:-
1. Letter No. GWPK/1107/2021, dated 07-05-2022 and 12-07-2022 from District Officer, Ground Water Department, Palakkad.
 2. Order No. T(1) 3075/2022/DGW dated: 18/07/2022 of Director, Groundwater Department, Thiruvananthapuram

ORDER

As per the letter read, the District Officer, Ground Water Department, Palakkad has forwarded a proposal for the construction of bore well at Panamkuttu, Parakkulam, Harijan Colony, Ward –XVII, Kizhakkenchery Grama Panchayath in Palakkad District for an estimated amount of Rs. 86,000/- (Rupees Eighty six thousand only) and requested for the sanction under Ground Water Based Drinking Water Supply Scheme.

The proposal for the construction of bore well, submitted by the District Officer has been verified and the amount is limited to Rs. 82,000/- (Rupees Eighty two thousand only).


As per the order read as 2nd paper Administrative sanction for an amount of Rs. 82,000/- (Rupees Eighty two thousand only) has been accorded by the Director of Groundwater Department for the above work.

After examining the matter in detail, technical sanction is hereby accorded to the District Officer, Ground Water Department, Palakkad for the construction of bore well at Panamkuttu, Parakkulam, Harijan Colony, Ward –XVII, Kizhakkenchery Grama

Panchayath in Palakkad District for an amount of Rs. 82,000/- (Rupees Eighty two thousand only).

The District Officer, Ground Water Department, Palakkad should ensure that the work should be carried out as per Government rules and that the scheme satisfies all the norms and conditions of Ground Water Based Drinking Water Supply Scheme. The work should be supervised by the technical staff of the Department. The District Officer should also make sure that the payment is made only as per the actual quantity and measurement of each item. The District Officer should forward detailed estimate for Water Supply Scheme as per the yield after construction of bore well.

The expenditure in this regard can be met from the budget provision of Rs. 400 lakhs under the Head of account "4702-00-102-94-01-scheme for Ground Water Based Drinking Water Scheme (P)" for the financial year 2022-2023. The date of completion of the scheme is to be intimated before the end of the financial year 2022-23.


Superintending Engineer (General) i/c

Encl: Corrected Estimate

To


1. The District Officer, Ground Water Department, Palakkad.
2. SE /EE/FO/OC/SF


Index : 1.3475

REVISED ESTIMATE OF CONSTRUCTION OF BOREWELL AT PANAMKUTTY-PARAKKALAM IN KIZHAKKANCHERY GP IN PALAKKAD DISTRICT UNDER GWBDWSS

Sl. No.	Particulars	Rate	Qty	Unit	Amount
1	Drilling charge for new 150 mm dia Borewell	665.00 ✓	100	m	66500 ✓
2	Cost of 180 mm ,6 Kg/cm ² ,ISI marked PVC casing pipe	682.97 683.43 ✓	7	m	4780.79 4784.01 ✓
3	Cost of 180 mm , PVC end cap	350.00 ✓	1	No.	350
4	Unforeseen				5189 X
Total					76823.01 71630.7
12 % GST(Excluding item 3)					9176.7612 8553.60
→ Unforeseen expenses : 1815.52					
Grand Total					86000
Rupees Eighty Six Thousand Only					<u>82,000</u>


Asst. Engineer



Asst. Executive Engineer


AE


EdE

7/12




DISTRICT OFFICER
District Officer
Groundwater Department
A-19, T.B. Complex
Palakkad - 378 014